

Information Sheet No 3. FIRE RESISTANT MATERIALS

According to the suppliers, the following materials comply with the requirements of AS 5601/AG 601 Gas Installations, Appendix C.

Other materials may also comply, check with supplier.

Proprietary name of material & minimum thickness required	M7AF Millboard (6 mm)	Supalux (9 mm) Monolux (12 mm)	Bellis Board (9 mm) Tacfire Insulation Board (9 mm)	Promina (12 mm) Promatect H (12 mm)
Thermal Conductivity	0.11 (M7AF)	0.17 (Supalux) 0.26 (Monolux)	0.17 (Bellis) 0.175 (Tacfire)	0.21 (Promina) 0.23 (Promatect)

If further information is required, please contact Helpline *on* 1300 366 322

Gas Standards and Safety wish to acknowledge the information provided by the Victorian Office of Gas Safety to assist in the preparation of this Information Sheet.