

Tasmanian Plumbing Code 1994

PART C2 - SYSTEM ACCREDITATION

No. 4

TYPE OF SYSTEM :	Aerated Waste Water Treatment System
TITLE:	Diston Rotating Biological Contactor and Underground Trickling filter unit, with Series 1, 2, 3, and 4 Biorotors.
APPLICANT:	Bradley Building Pty Ltd 516 Main Road or P O Box 134 Lilydale Tas 7268
MANUFACTURER:	Diston Sewage Purification Pty Ltd Factory 6 / 42 Burgess Road Nth Bayswater, Vic 3153
SYSTEM DESCRIPTION:	The system is an underground trickling contactor sewage treatment system .
SPECIFICATION:	As included in Diston Sewage Purification Pty Ltd specifications and drawings for Series 1, 2,3 and 4 systems
SUPPORTING DOCUMENTS:	Application of 27 February 1998 and supporting information. Letter of 25 March 1998 and supporting information. Letter of 8 August 1998 and supporting information.
CONDITIONS OF ACCREDITATION:	<p>The system shall not be installed in a plumbing installation other than in accordance with the conditions of a <i>Special Connection Permit</i> issued by the relevant Council under the <i>Plumbing Regulations 1994</i>. The conditions of the <i>Special Connection Permit</i> shall include the following:</p> <ul style="list-style-type: none">• Effluent from the system to be disinfected if it is to be processed in any manner other than conventional absorption trench disposal.• All plumbing work installed in connection with the system must comply with the <i>Tasmanian Plumbing Code</i>.• The system to comply with the <i>Guidelines for the installation and operation of aerobic waste water treatment systems</i> produced by the previous Tasmanian Department of Health.

- The owner of the system must enter into and maintain a Maintenance Contract with the Council or the Manufacturer [or a Council approved person].
- The Owner must enter into an Agreement with the Council to maintain a required Maintenance Contract with the Manufacturer [or a Council approved person] . The Agreement is to be binding on future owners and be registered against the land. [Section 55 of the *Local Government (Building and Miscellaneous Provisions) Act 1993*]
- The Manufacturer [or a Council approved person] must advise the Council immediately upon default of an Owner in not maintaining the Maintenance Contract.

NOTE:

In the event of an Owner's default in failing to comply with the conditions of the *Special Connection Permit*, the Council may take action to obtain compliance in accordance with the *Plumbing Regulations 1994*.

Date recommended by Building & Plumbing Regulations Board:	11 February 1999
Date Certificate of Accreditation issued by Minister:	24 March 1999