



Tasmanian Plumbing Code 1994

PART C1 - PRODUCT AUTHORISATION

No. P1

TYPE OF PRODUCT: Septic Tank Outlet Filter

TITLE: XtraTreat™ Septic Tank Outlet Filter

APPLICANT: Everhard Industries Pty Ltd
405 Newman Road
Geebung QLD 4034

MANUFACTURER: Everhard Industries Pty Ltd

PRODUCT DESCRIPTION: The Everhard filter uses filament wound tubes as a filter media and is placed in the outlet pipe of a septic tank. The filter media allows the liquid free passage where as large particles are retained to ensure further decomposition of the waste material in the tank.

SPECIFICATION: Drawings MP1918 and MP1742/7.

SUPPORTING DOCUMENTS: Application of 21 August 1997, supporting documents and drawings MP1918 and MP1742/7.

AUTHORISATION: The XtraTreat™ Septic Tank Outlet Filter as described in drawings MP1918 and MP1742/7 is authorised for use in plumbing installations in Tasmania in accordance with *Specification C1.8.3* of the *Tasmanian Plumbing Code 1994* subject to:

- *Published advice being provided with the packaging of the product to advise a purchaser of the requirements for safe cleaning of the filter.*

Date recommended by Building & Plumbing Regulations Board:	11 February 1999
Date Certificate of Authorisation issued by Minister:	24 March 1999