



Tasmanian Plumbing Code 1994

PART C2 - SYSTEM ACCREDITATION

No. 9

TYPE OF SYSTEM :	Aerated Waste Water Treatment System
TITLE:	Aqua SP2000 Wastewater Treatment Plant
APPLICANT:	Peter Harte Director Envirosep Sewage Treatment Australia 53-55 Canterbury Road Montrose Vic
MANUFACTURER:	Envirosep Sewage Treatment Australia
SYSTEM DESCRIPTION:	An aerated wastewater treatment system combining the process of aerobic biological treatment and mechanical filtration complete mix.
SPECIFICATION:	As included in the Envirosep Sewage Treatment Australia application and supporting documents.
SUPPORTING DOCUMENTS:	Application of 11 September 1998 and supporting documents.
CONDITIONS OF ACCREDITATION:	<p>The accreditation of the Aqua SP2000 Wastewater Treatment Plant is interim only at this stage. This interim accreditation allows for up to 3 systems to be installed. Each system is to undergo a minimum of 6 month testing arranged in conjunction with the relevant council and paid for by the applicant. Testing to include a 3 month full operational period during the winter months.</p> <p>Each system to be only located on a site which can be approved for the installation of a septic tank or other approved AWTS.</p> <p>The system shall not be installed in a plumbing installation other than in accordance with the conditions of a <i>Special Connection Permit</i> issued by the relevant Council under the <i>Plumbing Regulations 1994</i>. The conditions of the <i>Special Connection Permit</i> shall include the following:</p>

- All plumbing work installed in connection with the system must comply with the *Tasmanian Plumbing Code*.
- The system to comply with the *Guidelines for the installation and operation of aerobic waste water treatment systems* produced by the previous Tasmanian Department of Health.
- The owner of the system must enter into and maintain a Maintenance Contract with the Council or the Manufacturer [or a Council approved person].
- The Owner must enter into an Agreement with the Council to maintain a required Maintenance Contract with the Manufacturer [or a Council approved person] . The Agreement is to be binding on future owners and be registered against the land. [Section 55 of the *Local Government (Building and Miscellaneous Provisions) Act 1993*]
- The Manufacturer [or a Council approved person] must advise the Council immediately upon default of an Owner in not maintaining the Maintenance Contract.

NOTE:

In the event of an Owner's default in failing to comply with the conditions of the Special Connection Permit, the Council may take action to obtain compliance in accordance with the *Plumbing Regulations 1994*.

Date recommended by Building & Plumbing Regulations Board:	11 February 1999
Date Certificate of Accreditation issued by Minister:	24 March 1999