



Tasmanian Plumbing Code 1994

PART C2 - SYSTEM ACCREDITATION

No. 10

TYPE OF SYSTEM :	Aerated Waste Water Treatment System
TITLE:	Aqua-nova 2000 10 EP Sewage Treatment Plant
APPLICANT:	Harry van Heusden General Manager S B Engineering Pty Ltd 3 Old Pacific Highway or P O Box 51 Oxenford Qld 4210
MANUFACTURER:	S B Engineering Pty Ltd
SYSTEM DESCRIPTION:	A two stage anaerobic and aerobic sewage waste treatment system using two tanks with final chlorination disinfection of the effluent.
SPECIFICATION:	As included in S B Engineering Pty Ltd application and supporting documents.
SUPPORTING DOCUMENTS:	Application of 4 June 1998 and supporting documents. Letter of 15 June 1998 from applicant and supporting documents. Letter of 17 June 1998 from applicant and supporting documents. Letter of 6 August 1998 from applicant and supporting documents. Letter of 10 August 1998 from applicant and supporting documents. Letter of 19 August 1998 from applicant and supporting documents. Letter of 18 September 1998 from applicant and supporting documents. Owners Manual.
CONDITIONS OF ACCREDITATION:	<p>The accreditation of the Aqua-nova 2000 10 EP Sewage Treatment Plant is interim only at this stage. This interim accreditation allows for up to 3 systems to be installed. Each system is to undergo a minimum of 6 month testing arranged in conjunction with the relevant council and paid for by the applicant. Testing to include a 3 month full operational period during the winter months.</p> <p>Each system to be only located on a site which can be approved for the installation of a septic tank or other approved AWTS.</p>

The system shall not be installed in a plumbing installation other than in accordance with the conditions of a *Special Connection Permit* issued by the relevant Council under the *Plumbing Regulations 1994*. The conditions of the *Special Connection Permit* shall include the following:

- All plumbing work installed in connection with the system must comply with the *Tasmanian Plumbing Code*.
- The system to comply with the *Guidelines for the installation and operation of aerobic waste water treatment systems* produced by the previous Tasmanian Department of Health.
- The owner of the system must enter into and maintain a Maintenance Contract with the Council or the Manufacturer [or a Council approved person].
- The Owner must enter into an Agreement with the Council to maintain a required Maintenance Contract with the Manufacturer [or a Council approved person] . The Agreement is to be binding on future owners and be registered against the land. [Section 55 of the *Local Government (Building and Miscellaneous Provisions) Act 1993*]
- The Manufacturer [or a Council approved person] must advise the Council immediately upon default of an Owner in not maintaining the Maintenance Contract.

NOTE:

In the event of an Owner's default in failing to comply with the conditions of the Special Connection Permit, the Council may take action to obtain compliance in accordance with the *Plumbing Regulations 1994*.

Date recommended by Building & Plumbing Regulations Board:	11 February 1999
Date Certificate of Accreditation issued by Minister:	24 March 1999